

Volume calculation
for
Combustion Chamber Size

MODEL	PTR 92	JOB NUMBER									
VOLUME CALCULATION FOR AFTERBURNER CAPACITY OF FURNACES											
BASIC CALCULATION FOR VOLUME IS $(P1/P2) \times (T1 \times T2) = (V1/V2)$											
PRESSURE ESTIMATE AS MEAN FOR STD ATMOSPHERE							1015	TEMPERATURE ESTIMATE FOR STANDARD OPERATING		25	298
PRESSURE ESTIMATE AS MEAN FOR FURNACE INTERIOR							996	REQUIRED AFTERBURNER TEMPERATURE		850	1123
RATIO OF VOLUME INCREASE THROUGH FURNACE							3.8403			66	
FURNACE FUEL USAGE PER HOUR										6	
SPLIT 55% SECONDARY/45% PRIMARY											
BURNER	GAS	STOICHIOMETRIC AIR	50% EXCESS AIR	100% EXCESS AIR	TOTALS						
PRIMARY	3.3	33	0	33	69.3						
SECONDARY	2.7	27	13.5	0	43.2						
TOTAL GASES PASSING THROUGH FURNACE PER HOUR							112.5	VOLUME AT INCREASED TEMP		432.0388	
SPEED OF GASES PER SECOND							0.12001	M3/SEC			
REQUIRED HOLD TIME							2	SECONDS			
REQUIRED AFTERBURNER CAPACITY											
SQUARE SECTION LENGTH											
300 X 300	2.67	METRES									
350 X 350	1.96	METRES									
400 X 400	1.50	METRES									
550 x 400	1.09	METRES									
450 X 450	1.19	METRES									
500 X 500	0.96	METRES									
550 X 550	0.79	METRES									
600 X 600	0.67	METRES									
680 X 680	0.52	METRES									
750 X 750	0.43	METRES									
800 X 800	0.38	METRES									
1000 X 400	0.60	METRES									
ROUND SECTION LENGTH											
300 DIA	3.39	METRES									
350 DIA	2.50	METRES									
400 DIA	1.909479216	METRES									
450 DIA	1.50	METRES									
460 DIA	1.44	METRES									
500 DIA	1.22	METRES									
550 DIA	1.01	METRES									
600 DIA	0.85	METRES									