

Technical Note

Element Materials Technology

To: Craig Turnbull (Nissan Motor Manufacturing UK)
 From: Stephen Wigham (Element)
 Date: 02 May 2024
 Copy:
 Our reference: EMT09468-N001_Rev0
 Classification: Public

Subject: Stack Height Assessment – Proposed Pyrolysis Ovens, Sunderland Plant

In support of a permit variation application to Sunderland City Council, please find enclosed the results of the Stack Height Assessment conducted in accordance with the HMIP Technical Guidance Note D1 “Guidelines on Discharge Stack Heights for Polluting Materials”, June 1993.

The proposed operation falls under guidance provided by Process Guidance Note 2/09(13), statutory guidance for metal decontamination processes and installations, July 2013.

Relevant site plans are provided in **Appendix A**.

Background Air Quality Data

The existing air quality in the vicinity of the Nissan site is influenced by a combination of national background levels, industrial sources and traffic on the local road network together with domestic and other commercial sources.

The Nissan site is located within the Sunderland City Council area, which has not declared an Air Quality Management Area (AQMA).

The PM₁₀ concentration for the area is derived from the 2018 data set provided by UK AIR and adjusted for 2024. The average background value has been calculated for the nine 1 km x 1 km squares centred on 434500, 558500 (square occupied by the site). Estimates of VOC and HCl concentrations were derived from the UK Emissions Interactive Map.

The assumed background levels are provided in **Table 3**. The annual mean objective value is also given for comparison.

Table 1: Background concentrations

Pollutant		Predicted average figures	Annual mean objective (date) / EAL	
NO ₂	µg/m ³	12.53 (2023)	40	(2005)
VOC	mg/m ³	0.028	---	---
HCl	mg/m ³	0.0003	0.14	---

Background concentrations form approximately 31.33% and 0.21% of the PM₁₀ air quality standard and HCL EAL in this area respectively.

Estimated process emissions

Using worst-case emission concentration data provided by the pyrolysis oven manufacturer, **Table 2** details the main emission parameters that have been used in the assessment.

Table 2: Estimated emission parameters

Proposed emission point	Mass emission PM ₁₀ (g/s)	Mass emission VOC (g/s)	Mass emission HCL (g/s)	Gas temp. (°C)	Diameter of duct at release point (m)	Efflux velocity flow rate (m ³ /s)
PTR675 Pyrolysis Oven	0.001278	0.001611	0.000222	850	0.40	0.32003
PTR92 Pyrolysis Oven	0.000478	0.000597	0.000081	850	0.35	0.12001

Table 3: Permit limit requirements

Proposed emission point	PM ₁₀		VOC		HCL	
	Estimated emission (mg/m ³)	Permit limit (mg/m ³)	Estimated emission (mg/m ³)	Permit limit (mg/m ³)	Estimated emission (mg/m ³)	Permit limit (mg/m ³)
PTR675 Pyrolysis Oven	4.0	20	5.0	20	0.7	10
PTR92 Pyrolysis Oven	4.0	20	5.0	20	0.7	10

All supporting information can be found in **Appendix B**.

Assessment

Using the background concentrations and above estimated process emissions, guidance provided in the HMIP Technical Guidance Note D1 states that a stack height calculation is not possible due to the very low stack flow rate, negligible estimated emission concentrations and subsequent very low D1 Pollution Index concentration. This is supported by Section 5.7 of PG Note 2/09(13), which states:

“...where an emission consists purely of air and particulate matter, (i.e. no products of combustion or any other gaseous pollutants are emitted) the above provisions relating to stack height calculation for the purpose of dispersion and dilution should not normally be applied.”

The negligible estimated emission concentrations presented in **Table 2** would comply with the above criterion and a D1 calculation is not necessary, and in accordance with D1 Guidance, would not be accurate.

However, to align with best practice, Nissan have advised that all stacks associated with the pyrolysis ovens should have an exit point located a **minimum of +3.0m** above the Pyrolysis Building roof height. In the absence of a D1 calculation, this proposed stack height of the pyrolysis oven emission points is considered acceptable.

I trust that you find the above to be acceptable; however, should you require any further information please do not hesitate to contact me at any time.

Best regards,



Stephen Wigham BSc (Hons) MSc PgDip MIOA ACIEH AFPH

Principal Acoustic & Air Quality Consultant

Mob: [REDACTED]

Email: [REDACTED]

www.element.com




Appendix A

Site Plans




REV	DATE	BY	DESCRIPTION
1			ISSUED FOR CONSTRUCTION
2			ISSUED FOR CONSTRUCTION
3			ISSUED FOR CONSTRUCTION
4			ISSUED FOR CONSTRUCTION
5			ISSUED FOR CONSTRUCTION
6			ISSUED FOR CONSTRUCTION
7			ISSUED FOR CONSTRUCTION
8			ISSUED FOR CONSTRUCTION
9			ISSUED FOR CONSTRUCTION
10			ISSUED FOR CONSTRUCTION
11			ISSUED FOR CONSTRUCTION
12			ISSUED FOR CONSTRUCTION
13			ISSUED FOR CONSTRUCTION
14			ISSUED FOR CONSTRUCTION
15			ISSUED FOR CONSTRUCTION
16			ISSUED FOR CONSTRUCTION
17			ISSUED FOR CONSTRUCTION
18			ISSUED FOR CONSTRUCTION
19			ISSUED FOR CONSTRUCTION
20			ISSUED FOR CONSTRUCTION
21			ISSUED FOR CONSTRUCTION
22			ISSUED FOR CONSTRUCTION
23			ISSUED FOR CONSTRUCTION
24			ISSUED FOR CONSTRUCTION
25			ISSUED FOR CONSTRUCTION
26			ISSUED FOR CONSTRUCTION
27			ISSUED FOR CONSTRUCTION
28			ISSUED FOR CONSTRUCTION
29			ISSUED FOR CONSTRUCTION
30			ISSUED FOR CONSTRUCTION
31			ISSUED FOR CONSTRUCTION
32			ISSUED FOR CONSTRUCTION
33			ISSUED FOR CONSTRUCTION
34			ISSUED FOR CONSTRUCTION
35			ISSUED FOR CONSTRUCTION
36			ISSUED FOR CONSTRUCTION
37			ISSUED FOR CONSTRUCTION
38			ISSUED FOR CONSTRUCTION
39			ISSUED FOR CONSTRUCTION
40			ISSUED FOR CONSTRUCTION
41			ISSUED FOR CONSTRUCTION
42			ISSUED FOR CONSTRUCTION
43			ISSUED FOR CONSTRUCTION
44			ISSUED FOR CONSTRUCTION
45			ISSUED FOR CONSTRUCTION
46			ISSUED FOR CONSTRUCTION
47			ISSUED FOR CONSTRUCTION
48			ISSUED FOR CONSTRUCTION
49			ISSUED FOR CONSTRUCTION
50			ISSUED FOR CONSTRUCTION
51			ISSUED FOR CONSTRUCTION
52			ISSUED FOR CONSTRUCTION
53			ISSUED FOR CONSTRUCTION
54			ISSUED FOR CONSTRUCTION
55			ISSUED FOR CONSTRUCTION
56			ISSUED FOR CONSTRUCTION
57			ISSUED FOR CONSTRUCTION
58			ISSUED FOR CONSTRUCTION
59			ISSUED FOR CONSTRUCTION
60			ISSUED FOR CONSTRUCTION
61			ISSUED FOR CONSTRUCTION
62			ISSUED FOR CONSTRUCTION
63			ISSUED FOR CONSTRUCTION
64			ISSUED FOR CONSTRUCTION
65			ISSUED FOR CONSTRUCTION
66			ISSUED FOR CONSTRUCTION
67			ISSUED FOR CONSTRUCTION
68			ISSUED FOR CONSTRUCTION
69			ISSUED FOR CONSTRUCTION
70			ISSUED FOR CONSTRUCTION
71			ISSUED FOR CONSTRUCTION
72			ISSUED FOR CONSTRUCTION
73			ISSUED FOR CONSTRUCTION
74			ISSUED FOR CONSTRUCTION
75			ISSUED FOR CONSTRUCTION
76			ISSUED FOR CONSTRUCTION
77			ISSUED FOR CONSTRUCTION
78			ISSUED FOR CONSTRUCTION
79			ISSUED FOR CONSTRUCTION
80			ISSUED FOR CONSTRUCTION
81			ISSUED FOR CONSTRUCTION
82			ISSUED FOR CONSTRUCTION
83			ISSUED FOR CONSTRUCTION
84			ISSUED FOR CONSTRUCTION
85			ISSUED FOR CONSTRUCTION
86			ISSUED FOR CONSTRUCTION
87			ISSUED FOR CONSTRUCTION
88			ISSUED FOR CONSTRUCTION
89			ISSUED FOR CONSTRUCTION
90			ISSUED FOR CONSTRUCTION
91			ISSUED FOR CONSTRUCTION
92			ISSUED FOR CONSTRUCTION
93			ISSUED FOR CONSTRUCTION
94			ISSUED FOR CONSTRUCTION
95			ISSUED FOR CONSTRUCTION
96			ISSUED FOR CONSTRUCTION
97			ISSUED FOR CONSTRUCTION
98			ISSUED FOR CONSTRUCTION
99			ISSUED FOR CONSTRUCTION
100			ISSUED FOR CONSTRUCTION

PROJECT: PYROLYSIS OVEN INSTALLATION
 (Production and Refurbishment)
 DRAWN: C. T. B. J. F. L.
 DATE: Feb. 24
 SCALE: 1:500
 SHEET NO. 00
 DRAWING NO. 00



Paint Removal Building



• Test Point

Revision	Original	
APPROVED	DESCRIPTION	
RT / CT	NISSAN MOTOR MANUFACTURING (UK) LTD.	
CHECKED	PROJECT	
CT	PYROLYSIS OVEN INSTALLATION (Fluidised bed replacement)	
DRAWN	TITLE	
RT	Controlled Pyrolysis Cleaning Ovens	
DATE	08th Feb 24	
SCALE	DRAWING No	SHEET
NTS	RTCT080224	1

CONTROLLED PYROLYSIS™ FOR CLEANER AIR

ENVIRONMENTAL EMISSIONS

Listed below is information that relates to the latest results of emission tests carried out by BSI (British Standards Institute) for environment requirements on Pollution Control Furnaces. Listed below are the results from 2004,2010 and 2014 against current European limits.

Emission Standards

Component	Test Results 2004	Test Results 2010	Test Results 2014	Limit Values mg/m ³				
				UK	Germany	Netherlands	Belgium	Spain
Total Particulate mg/m ³ note 1	1.38	0.5	4	50	20	25	30	10
VOC as C mg/m ³ Organic compounds	5.5	5.0	1.2	20	20	50	30	10
CO Carbon Monoxide	0.0010%	0.0006%	0.0009%	100	100	100	100	100
H ₂ O % Water vapour	3	3	3					
CO ₂ % Carbon Dioxide	5.7	7.6	7.4					9
O ₂ % Oxygen	11	11	11	11	11	11	11	
HCl mg/m ³ Hydrogen chloride	0.00	0.00	0.7	100	20	Unknown	Unknown	7
Afterburner Temperature	850°C	850°C	850°C 2 second dwell period	850°C	850°C 2 second dwell period	850°C 2 second dwell period	850°C 2 second dwell period	850°C 2 second dwell period

Notes

1. Values correspond to 2014 limits.
2. Results of emission concentrations expressed @ 11% oxygen, 273K, 101.0kPa dry gas per current EPA testing standards.
3. 800ppm equals 100mg/m³

Volume calculation
for
Combustion Chamber Size

MODEL	PTR 675	JOB NUMBER							
VOLUME CALCULATION FOR AFTERBURNER CAPACITY OF FURNACES									
BASIC CALCULATION FOR VOLUME IS $(P1/P2) \times (T1 \times T2) = (V1/V2)$								CELCIUS	KELVIN
PRESSURE ESTIMATE AS MEAN FOR STD ATMOSPHERE		1015	TEMPERATURE ESTIMATE FOR STANDARD OPERATING		25	298			
PRESSURE ESTIMATE AS MEAN FOR FURNACE INTERIOR		996	REQUIRED AFTERBURNER TEMPERATURE		850	1123			
RATIO OF VOLUME INCREASE THROUGH FURNACE			3.8403	66					
FURNACE FUEL USAGE PER HOUR			16						
SPLIT 55% SECONDARY/45% PRIMARY									
BURNER	GAS	STOICHIOMETRIC AIR	50% EXCESS AIR	100% EXCESS AIR	TOTALS				
PRIMARY	8.8	88	0	88	184.8				
SECONDARY	7.2	72	36	0	115.2				
TOTAL GASES PASSING THROUGH FURNACE PER HOUR		300	VOLUME AT INCREASED TEMP		1152.103				
SPEED OF GASES PER SECOND		0.32003	M3/SEC						
REQUIRED HOLD TIME		2 SECONDS							
REQUIRED AFTERBURNER CAPACITY									
SQUARE SECTION LENGTH									
300 X 300	7.11	METRES							
350 X 350	5.22	METRES							
400 X 400	4.00	METRES							
550 x 400	2.91	METRES							
450 X 450	3.16	METRES							
500 X 500	2.56	METRES							
550 X 550	2.12	METRES							
600 X 600	1.78	METRES							
680 X 680	1.38	METRES							
750 X 750	1.14	METRES							
800 X 800	1.00	METRES							
1000 X 400	1.60	METRES							
ROUND SECTION LENGTH									
300 DIA	9.05	METRES							
350 DIA	6.65	METRES							
400 DIA	5.09	METRES							
450 DIA	4.01	METRES							
460 DIA	3.85	METRES							
500 DIA	3.26	METRES							
550 DIA	2.69	METRES							
600 DIA	2.26	METRES							

Volume calculation
for
Combustion Chamber Size

MODEL	PTR 92	JOB NUMBER							
VOLUME CALCULATION FOR AFTERBURNER CAPACITY OF FURNACES									
BASIC CALCULATION FOR VOLUME IS $(P1/P2) \times (T1 \times T2) = (V1/V2)$									
							CELCIUS	KELVIN	
PRESSURE ESTIMATE AS MEAN FOR STD ATMOSPHERE		1015		TEMPERATURE ESTIMATE FOR STANDARD OPERATING			25	298	
PRESSURE ESTIMATE AS MEAN FOR FURNACE INTERIOR		996		REQUIRED AFTERBURNER TEMPERATURE			850	1123	
RATIO OF VOLUME INCREASE THROUGH FURNACE				3.8403		66			
FURNACE FUEL USAGE PER HOUR				6					
SPLIT 55% SECONDARY/45% PRIMARY									
BURNER	GAS	STOICHIOMETRIC AIR	50% EXCESS AIR	100% EXCESS AIR	TOTALS				
PRIMARY	3.3	33	0	33	69.3				
SECONDARY	2.7	27	13.5	0	43.2				
TOTAL GASES PASSING THROUGH FURNACE PER HOUR			112.5	VOLUME AT INCREASED TEMP		432.0388			
SPEED OF GASES PER SECOND		0.12001	M3/SEC						
REQUIRED HOLD TIME		2 SECONDS							
REQUIRED AFTERBURNER CAPACITY									
SQUARE SECTION LENGTH									
300 X 300	2.67		METRES						
350 X 350	1.96		METRES						
400 X 400	1.50		METRES						
550 x 400	1.09		METRES						
450 X 450	1.19		METRES						
500 X 500	0.96		METRES						
550 X 550	0.79		METRES						
600 X 600	0.67		METRES						
680 X 680	0.52		METRES						
750 X 750	0.43		METRES						
800 X 800	0.38		METRES						
1000 X 400	0.60		METRES						
ROUND SECTION LENGTH									
300 DIA	3.39		METRES						
350 DIA	2.50		METRES						
400 DIA	1.909479216		METRES						
450 DIA	1.50		METRES						
460 DIA	1.44		METRES						
500 DIA	1.22		METRES						
550 DIA	1.01		METRES						
600 DIA	0.85		METRES						

PCP OVEN SERVICES LTD

BASEPOINT BUSINESS CENTRE
HAYWARDS HEATH
WEST SUSSEX
RH16 1UA

Contents,

2-Second Retention Afterburner
Calculations for a Model PRC 1508L
Pyrolysis Furnace manufactured by
Pollution Control Products Co And
PCP Oven Services Ltd

These calculations are based on a standard mathematical calculation used throughout industry to obtain air and gas flow volumes through equipment.

Stack Heights and afterburner sizes use this method of “Stoichiometric Ratio” .

Enclosed is all the supporting documentation required to follow the methodology of the calculation.

The Excel Spreadsheet marked shows the basic calculations and conclusions. The final figure of 5.09m is highlighted in green .

1. Shown is the mean atmospheric pressure divided by the estimated furnace interior pressure or $(1015/996=1.02)$.
2. Standard operating temperature, this figure is determined due to the high levels of heat involved in painting lines, inline curing and drying ovens create a high ambient working temperature. This is divided into the required temperature of 850 degrees C. $(1123/298= 3.77)$
3. These two figures are then multiplied together to give the ratio of volume increase $(1.02 \times 3.77 = 3.8403)$.
4. Furnace fuel usage is calculated using the correlation between gas pressure and burner output. The burner head gas pressure was measured during commissioning of the equipment and recorded on the commissioning sheet (D). If you refer to the burner manuals on page three the graph will give you a guide Kilowatt value. We have assumed both of these values to be 80 kw per burner.
5. Given the combined fuel usage of 160 kw/hr this is multiplied by 0.097 (standard conversion kw to m³) to give the figure 15.52m³/hr of gas.

6. For the purposes of the original calculation Pollution Control Products have added extra gas usage for a safety margin and rounded the figure to 16 m³/hr.
7. The gas usage figure is then divided between the secondary and primary burners and the gas to air stoichiometric ratio is applied. The totals are added together to give the gases passing through the furnace per hour at 300m³/hr. Multiply this by the volume increase ratio and you have your volume at increased temperature, (184.8+115.2*3.8403= 1152.1034)
8. The volume is then divided by 3600 to give you the speed of gases (1152.1034/3600=0.32003).
9. This figure is then multiplied by the 2 seconds required divided by the cross sectional area of the afterburner chamber to give a minimum length requirement shown for 400 ID stack as 5.09m.
10. Some variations can occur due to a damaged door seal the atmospheric pressure in the furnace chamber is equal to the outside, ambient temperature (winter time) would be 5°C.

Conclusion and variation Summary.

The actual afterburner distance between inlet and temperature measurement point is 5.5 m.

Pollution Control Products Co consider the calculations to be correct and with the actual distance measured at 5.5m feel a good level of safety margin has been added.